



ENERGY STAR® Statement of Energy Performance

90

ENERGY STAR®
Score¹

DPHHS Headquarters

Primary Property Function: Office
Gross Floor Area (ft²): 48,682
Built: 1975

For Year Ending: April 30, 2013
Date Generated: April 22, 2014

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information

Property Address
DPHHS Headquarters
111 North Sanders
Helena, Montana 59620

Property Owner
Montana Department of Environmental
Quality
1520 E 6th Ave
Helena, MT 59601-4541
406-444-6460

Primary Contact
Ronald Pecarina
1520 E 6th Ave
Helena, MT 59620
4064446590
rpecarina@mt.gov

Property ID: 4030096

Energy Consumption and Energy Use Intensity (EUI)

Site EUI		Annual Energy by Fuel		National Median Comparison	
60.3 kBtu/ft²	Natural Gas (kBtu)	1,355,000	(46%)	National Median Site EUI (kBtu/ft²)	111.5
	Electric - Grid (kBtu)	1,582,392	(54%)	National Median Source EUI (kBtu/ft²)	242.7
				% Diff from National Median Source EUI	-46%
Source EUI		Annual Emissions			
131.3 kBtu/ft²		Greenhouse Gas Emissions (MtCO2e/year)		245	

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: _____ Date: _____

Licensed Professional

Ronald Pecarina
1520 E 6th Ave
Helena, MT 59620
4064446590
rpecarina@mt.gov



Professional Engineer Stamp
(if applicable)